

## Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

**Location:** AUGUSTA SERVICE STATION LLP  
 MAIN ST  
 AUGUSTA, MT 59410 LEWIS AND CLARK  
**Contact:** Ben E Arps, (406) 562-3377

**Sys Fac ID:** 25-02114  
**Last Inspected On:** 6/13/2014  
**Operating Permit Renewal Date:** 8/22/2017

**Owners/Operators:** Ben E Arps Exxon, Owner (406)-562-3377 PO BOX 58  
 AUGUSTA MT 59410-0058  
 Benjamin E Arps, UST Class A Operator  
 Benjamin E Arps, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	26	6/6/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3950</b>			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/8/2008	Stat. Inventory Reconciliation	Deferred	
1,500					
2	26	6/6/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3951</b>			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/8/2008	Stat. Inventory Reconciliation	Deferred	
750					
6	26	6/6/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3952</b>			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/8/2008	Stat. Inventory Reconciliation	Deferred	
750					

## Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

**Location:** MALMSTROM AFB F 5  
MT HIGHWAY 21  
AUGUSTA, MT 59410 LEWIS AND CLARK

**Sys Fac ID:** 25-09034  
**Last Inspected On:** 9/17/2015  
**Operating Permit Renewal Date:** 9/22/2018

**Contact:** Jim Hodges,

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
MALMSTROM AFB MT 59402-7536  
Lana Hedlund, UST Class A Operator  
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
<b>247</b>		6/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

**Location:** MALMSTROM AFB F 6  
 US HIGHWAY 287  
 AUGUSTA, MT 59410 LEWIS AND CLARK

**Sys Fac ID:** 25-09035  
**Last Inspected On:** 9/17/2015  
**Operating Permit Renewal Date:** 9/22/2018

**Contact:** Jim Hodges,

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
 MALMSTROM AFB MT 59402-7536  
 Lana Hedlund, UST Class A Operator  
 Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
248		6/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

**Location:** MALMSTROM AFB F 7  
ROAD 434  
AUGUSTA, MT 59410 LEWIS AND CLARK

**Sys Fac ID:** 25-09036  
**Last Inspected On:** 9/17/2015  
**Operating Permit Renewal Date:** 9/22/2018

**Contact:** Jim Hodges,

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
MALMSTROM AFB MT 59402-7536  
Lana Hedlund, UST Class A Operator  
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
<b>249</b>		6/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

## Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

**Location:** MALMSTROM AFB G 9  
US HIGHWAY 287  
AUGUSTA, MT 59410 LEWIS AND CLARK

**Sys Fac ID:** 25-09049  
**Last Inspected On:** 9/21/2015  
**Operating Permit Renewal Date:** 9/23/2018

**Contact:** Jim Hodges,

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator  
James Hodges, UST Class A Operator  
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
<b>254</b>		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

## Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

**Location:** MALMSTROM AFB G 10  
 US HIGHWAY 287  
 AUGUSTA, MT 59410 LEWIS AND CLARK

**Sys Fac ID:** 25-09050

**Last Inspected On:** 9/21/2015

**Operating Permit Renewal Date:** 9/23/2018

**Contact:** Jim Hodges,

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
 MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
255		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

## Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

**Location:** MALMSTROM AFB F 1  
US HIGHWAY 287  
AUGUSTA, MT 59410 LEWIS AND CLARK

**Sys Fac ID:** 50-09030

**Last Inspected On:** 9/17/2015

**Operating Permit Renewal Date:** 9/22/2018

**Contact:** Jim Hodges,

---

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator  
Ricardo Andrillon, UST Class B Operator  
Glen Beck, UST Class B Operator  
Allen Brooks, UST Class B Operator  
Jonathan Buesch, UST Class B Operator  
John Corbett, UST Class B Operator  
David Cosner, UST Class B Operator  
Ryan Cox, UST Class B Operator  
Brian Day, UST Class B Operator  
David Degolier, UST Class B Operator  
Patrick Ellis, UST Class B Operator  
Hudson English, UST Class B Operator  
Paul Floyd, UST Class B Operator  
Dustin Hemingway, UST Class B Operator  
Aaron Hill, UST Class B Operator  
William Hoffmeister, UST Class B Operator  
Shane Hofstad, UST Class B Operator  
Bethany Kent, UST Class B Operator  
James Knudsen, UST Class B Operator  
Ryan Kofoed, UST Class B Operator  
Jeff Laird, UST Class B Operator  
Damon McCarty, UST Class B Operator  
Kieth McIlwain, UST Class B Operator  
Brian McVay, UST Class B Operator  
Ronald Miller, UST Class B Operator  
Michael Murieen, UST Class B Operator  
Jeff Nelson, UST Class B Operator  
Patrick Noppenberg, UST Class B Operator  
Shawn O'Grady, UST Class B Operator  
Chris Ploof, UST Class B Operator  
Issac Price, UST Class B Operator  
Brian Rayner, UST Class B Operator

## Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

**Location:** MALMSTROM AFB F 1  
US HIGHWAY 287  
AUGUSTA, MT 59410      LEWIS AND CLARK

**Sys Fac ID:** 50-09030  
**Last Inspected On:** 9/17/2015  
**Operating Permit Renewal Date:** 9/22/2018

**Contact:** Jim Hodges,  
Cameron Smith, UST Class B Operator  
Jimmy Sonefelt, UST Class B Operator  
Michael Stokes, UST Class B Operator  
Kyle Topp, UST Class B Operator  
Jason Vike, UST Class B Operator  
James Wooderchak, UST Class B Operator  
Paul Ziemba, UST Class B Operator  
Paul Floyd, UST Class B Global Operator  
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	53	6/2/1962	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff, High Level Alarm
303		6/11/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		7/31/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		



## Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

**Location:** CANYON FERRY MINI BASKET  
3012 CANYON FERRY RD  
EAST HELENA, MT 59635 LEWIS AND CLARK

**Sys Fac ID:** 25-03122

**Last Inspected On:** 2/5/2016

**Operating Permit Renewal Date:** 3/30/2019

**Contact:** Robert Merzlak, (406) 227-8506

**Owners/Operators:** Big Sky Food and Fuel Inc, Owner

(406)-443-3608

ROBER J MERZLAK  
3012 CANYON FERRY RD  
EAST HELENA MT 59635-3025

Robert J Merzlak, UST Class A Operator

Robert J Merzlak, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2319</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/13/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	08	10/16/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>5151</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		10/13/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
5	08	10/16/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>5152</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		10/13/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

## Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

**Location:** TOWN PUMP INC EAST HELENA  
418 W MAIN ST  
EAST HELENA, MT 59635 LEWIS AND CLARK  
**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 25-08697  
**Last Inspected On:** 3/25/2013  
**Operating Permit Renewal Date:** 6/29/2016

**Owners/Operators:** Town Pump of East Helena Inc, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	47	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4672</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/14/2013	Automatic Tank Gauging 0.2, Stat. Inventory	Automatic Tank Gauging 0.2, Stat. Inventory	
12,000			Reconciliation, Approved Remote Monitoring	Reconciliation, Approved Remote Monitoring	
2	47	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4673</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/14/2013	Automatic Tank Gauging 0.2, Stat. Inventory	Automatic Tank Gauging 0.2, Stat. Inventory	
12,000			Reconciliation, Approved Remote Monitoring	Reconciliation, Approved Remote Monitoring	
3	47	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4674</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/14/2013	Automatic Tank Gauging 0.2, Stat. Inventory	Automatic Tank Gauging 0.2, Stat. Inventory	
8,000			Reconciliation, Approved Remote Monitoring	Reconciliation, Approved Remote Monitoring	
4	47	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4675</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/14/2013	Automatic Tank Gauging 0.2, Stat. Inventory	Automatic Tank Gauging 0.2, Stat. Inventory	
3,000			Reconciliation, Approved Remote Monitoring	Reconciliation, Approved Remote Monitoring	

## Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

**Location:** TOWN PUMP INC EAST HELENA  
 418 W MAIN ST  
 EAST HELENA, MT 59635 LEWIS AND CLARK  
**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 25-08697  
**Last Inspected On:** 3/25/2013  
**Operating Permit Renewal Date:** 6/29/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	47	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4676</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/14/2013	Automatic Tank Gauging 0.2, Stat. Inventory	Automatic Tank Gauging 0.2, Stat. Inventory	
			Reconciliation, Approved Remote Monitoring	Reconciliation, Approved Remote Monitoring	
4,000					
6	38	4/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4677</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/14/2013	Automatic Tank Gauging 0.2, Stat. Inventory	Automatic Tank Gauging 0.2, Stat. Inventory	
			Reconciliation, Approved Remote Monitoring	Reconciliation, Approved Remote Monitoring	
6,000					
7	38	4/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4678</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/14/2013	Automatic Tank Gauging 0.2, Stat. Inventory	Automatic Tank Gauging 0.2, Stat. Inventory	
			Reconciliation, Approved Remote Monitoring	Reconciliation, Approved Remote Monitoring	
6,000					

## Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

**Location:** TOWN PUMP OF EAST HELENA #2  
 116 LANE AVE  
 EAST HELENA, MT 59635 LEWIS AND CLARK  
**Contact:** Roger Hovis, (406) 227-9170

**Sys Fac ID:** 56-13915  
**Last Inspected On:** 3/25/2013  
**Operating Permit Renewal Date:** 6/29/2016

**Owners/Operators:** Miles City Holdings LLC, Owner (406)-497-6700 PO BOX 6000  
 BUTTE MT 59702-6000  
 Trent Biggers, UST Class A Operator  
 Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4028</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
2	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4029</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
3	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4030</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000					

## Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

**Location:** TOWN PUMP OF EAST HELENA #2  
 116 LANE AVE  
 EAST HELENA, MT 59635 LEWIS AND CLARK  
**Contact:** Roger Hovis, (406) 227-9170

**Sys Fac ID:** 56-13915  
**Last Inspected On:** 3/25/2013  
**Operating Permit Renewal Date:** 6/29/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4031</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000					
5	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4032</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000					
6	16	3/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4033</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000					
7	12	8/18/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4861</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					

## Facility Summary in LEWIS AND CLARK County in the City of FORT HARRISON

**Location:** VETERANS HEALTH ADMINISTRATION  
 3687 VETERANS DRIVE BLDG 141  
 FORT HARRISON, MT 59636 LEWIS AND CLARK  
**Contact:** Kailen Collette, (406) 447-7382

**Sys Fac ID:** 25-05908  
**Last Inspected On:** 1/7/2015  
**Operating Permit Renewal Date:** 2/3/2018

**Owners/Operators:** US Dept of Veterans Affairs, Owner (406)-447-7121 FORT HARRISON  
 3687 VETERANS DRIVE 085B  
 FORT HARRISON MT 59636  
 Kailen Collette, Operator (406)-447-7382 3687 VETERANS DRIVE  
 FORT HARRISON MT 59636  
 Michael Harris, UST Class A Operator  
 Leslie Holz, UST Class A Operator  
 Steven Felter, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>2214</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>2216</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
4,000		6/13/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
13	05	10/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>5278</b>		7/1/2011	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/13/2013	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.2	Yes

## Facility Summary in LEWIS AND CLARK County in the City of FORT HARRISON

**Location:** VETERANS HEALTH ADMINISTRATION  
 3687 VETERANS DRIVE BLDG 141  
 FORT HARRISON, MT 59636 LEWIS AND CLARK  
**Contact:** Kailen Collette, (406) 447-7382

**Sys Fac ID:** 25-05908  
**Last Inspected On:** 1/7/2015  
**Operating Permit Renewal Date:** 2/3/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
14	03	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>5366</b>		5/24/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000		3/30/2015	TLS-450 , Veeder Root		Yes

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** EXEC AIR MONTANA INC 1  
2430 AIRPORT RD  
HELENA, MT 59601 LEWIS AND CLARK

**Contact:** John Maxness, (406) 442-2190

**Sys Fac ID:** 25-00642  
**Last Inspected On:** 6/4/2013  
**Operating Permit Renewal Date:** 10/23/2016

**Owners/Operators:** Exec Air Montana Inc, Owner (406)-442-2190 2560 AIRPORT RD  
HELENA MT 59601-1207

John Maxness, UST Class A Operator  
John Maxness, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	24	6/1/1991	Cathodically Protected Steel	No Piping	High Level Alarm
<b>3344</b>			Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Aviation Gas		9/23/2013	Continuous Interstitial Monitor		
12,000					
6	24	6/1/1991	Cathodically Protected Steel	No Piping	High Level Alarm
<b>3345</b>			Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	Galvanic
Jet Fuel		9/23/2013	Continuous Interstitial Monitor		
12,000					



## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** COMBINED CRIMINAL JUSTICE FACILITY  
221 BRECKENRIDGE ST  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-00945

**Last Inspected On:** 7/11/2013

**Operating Permit Renewal Date:** 10/31/2016

**Contact:** Dave Schmitted, (406) 447-8299

**Owners/Operators:** Lewis & Clark County Jail, Owner (406)-447-8299 228 E BROADWAY ST RM 5  
HELENA MT 59601-4263

Kirk Ketchum, UST Class A Operator  
Robert McCarley, UST Class A Operator  
David Schmitz, UST Class A Operator  
Kirk Ketchum, UST Class B Global Operator  
Robert McCarley, UST Class B Global Operator  
David Schmitz, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	4/21/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>4060</b>		7/10/2013	None	Double-Walled	Yes
Currently in Use		4/21/1995	Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		7/11/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
3,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** KIMS MARINA & RESORT  
8015 CANYON FERRY RD  
HELENA, MT 59602 LEWIS AND CLARK

**Sys Fac ID:** 25-01091

**Last Inspected On:** 3/13/2014

**Operating Permit Renewal Date:** 5/10/2017

**Contact:** Greg Axtman, (406) 475-3195

**Owners/Operators:** Greg Axtman, Owner (406)-475-3195 3980 LAKE HILLS LN  
HELENA MT 59602-8503

Greg Axtman, UST Class A Operator  
Maryann Axtman, UST Class A Operator  
Greg Axtman, UST Class B Operator  
Maryann Axtman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	22	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3516			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
3,782		5/5/2014		Continuous Interstitial Monitor	

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** HELENA SERVICE CENTER  
1315 N LAST CHANCE GULCH  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-01183

**Last Inspected On:** 3/14/2014

**Operating Permit Renewal Date:** 8/12/2017

**Contact:** Beth Stimatz, (406) 497-2687

**Owners/Operators:** Northwestern Energy, Owner (406)-497-3382 ATTN: BETH STIMATZ  
40 E BROADWAY ST  
BUTTE MT 59701-9394

John Habeger, UST Class A Operator  
Phil Hatfield, UST Class A Operator  
Eric Brass, UST Class B Operator  
Joyce Walczak, UST Class B Operator  
Phil Hatfield, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	17	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1678</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	17	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1679</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** FRIENDLYS SINCLAIR  
1831 11TH AVE  
HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** Barb Leland, (406) 442-4865

**Sys Fac ID:** 25-01314  
**Last Inspected On:** 5/28/2014  
**Operating Permit Renewal Date:** 7/26/2017

**Owners/Operators:** Barbara Leland, Owner (406)-442-4865 1831 11TH AVE  
HELENA MT 59601-4769  
Edward Dimock, UST Class A Operator  
Ginny Helfert, UST Class A Operator  
Barbara Leland, UST Class A Operator  
Edward Dimock, UST Class B Operator  
Scott Leland, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	14	1/2/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4611</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		6/15/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
6	14	1/2/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4612</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		6/15/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
7	14	1/2/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4613</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
20,000		6/15/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** PHILLIPS 66 HELENA TERMINAL  
3180 E US HWY 12 PO BOX 30198  
HELENA, MT 59601 LEWIS AND CLARK

**Contact:** Dale Waltrip, (406) 442-6395

**Sys Fac ID:** 25-01846

**Last Inspected On:** 11/11/2015

**Operating Permit Renewal Date:** 11/13/2018

<b>Owners/Operators:</b>	Phillips 66 Helena Terminal, Owner	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101
	Phillips 66 Pipeline LLC, Operator	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101
	Brian Buckley, UST Class A Operator		
	CHARLES HEINAMAN, UST Class A Operator		
	Ryan Norwood, UST Class A Operator		
	John Stampfli, UST Class A Operator		
	Steve Thomas, UST Class A Operator		
	Brian Buckley, UST Class B Operator		
	Theodore Hagemo, UST Class B Operator		
	Ryan Norwood, UST Class B Operator		
	James Olson, UST Class B Operator		
	Clifford Pearce, UST Class B Operator		
	Steven Sheldon, UST Class B Operator		
	Steve Thomas, UST Class B Operator		
	Michael Crawford, UST Class B Global Operator		
	CHARLES HEINAMAN, UST Class B Global Operator		
	Richard Leeds, UST Class B Global Operator		
	Jeb Pedrazzi, UST Class B Global Operator		
	John Stampfli, UST Class B Global Operator		
	Dane Whittaker, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	1/1/1993	Fiberglass Reinforced Plastic	Steel	High Level Alarm
4919			Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Not Applicable, Impressed Current
Mixture		5/12/2015	Continuous Interstitial Monitor	MLLD Line Tightness Testing	
10,000		11/11/2015	Other , Other		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** EXEC AIR MONTANA INC 2  
2430 AIRPORT RD  
HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** John Maxness, (406) 442-2190

**Sys Fac ID:** 25-02123  
**Last Inspected On:** 6/4/2013  
**Operating Permit Renewal Date:** 6/12/2016

**Owners/Operators:** Exec Air Montana Inc, Owner (406)-442-2190 2560 AIRPORT RD  
HELENA MT 59601-1207  
John Maxness, UST Class A Operator  
John Maxness, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	49	4/1/1966	Bare Steel	No Piping	High Level Alarm
<b>3646</b>			Impressed Current	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Jet Fuel		9/11/2013	Vapor Monitoring		
15,000					
2	49	4/1/1966	Bare Steel	No Piping	High Level Alarm
<b>3647</b>			Impressed Current	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Jet Fuel		9/11/2013	Vapor Monitoring		
15,000					
3	49	4/1/1966	Bare Steel	No Piping	High Level Alarm
<b>3648</b>			Impressed Current	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Gasoline		9/11/2013	Vapor Monitoring		
15,000					
4	49	4/1/1966	Bare Steel	No Piping	High Level Alarm
<b>3649</b>			Impressed Current	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Gasoline		9/11/2013	Vapor Monitoring		
15,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** CEDAR STREET CONOCO  
1701 CEDAR ST  
HELENA, MT 59601 LEWIS AND CLARK

**Contact:** Mike Salois, (406) 459-8719

**Sys Fac ID:** 25-03466  
**Last Inspected On:** 5/8/2015  
**Operating Permit Renewal Date:** 6/11/2018

**Owners/Operators:** Cedar Street Conoco, Owner (406)-495-0953 1701 CEDAR STREET  
HELENA MT 59601

Michael Salois, Operator (406)-459-8719 2965 SUNNYSIDE  
HELENA MT 59602

Michael Salois, UST Class A Operator  
Daren Griffeth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	17	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>2228</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
6	17	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>2229</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
7	17	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>2230</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** UNITED PARCEL SERVICE HELENA  
3029 AIRPORT RD  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-04538  
**Last Inspected On:** 1/31/2013  
**Operating Permit Renewal Date:** 6/1/2016

**Contact:** Ron Kenney, (406) 449-3505

---

**Owners/Operators:** United Parcel Service, Inc, Owner (206)-621-6233 4455 7TH AVENUE S  
SEATTLE WA 98108  
United Parcel Service Plant Engineering Dept, Operator (206)-621-6261 4455 7TH AVE S  
SEATTLE WA 98108  
Robert Counts, UST Class A Operator  
Treaire Smith, UST Class A Operator  
Russell Stott, UST Class A Operator  
Paul Vandehey, UST Class A Operator  
Robert Counts, UST Class B Operator  
Russell Stott, UST Class B Operator  
Treaire Smith, UST Class B Global Operator  
Paul Vandehey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4446			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		1/31/2013			



## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** JOLLY OS GAS N GO  
1200 CEDAR ST  
HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** (406) 442-5621

**Sys Fac ID:** 25-04966  
**Last Inspected On:** 3/7/2013  
**Operating Permit Renewal Date:**

**Owners/Operators:** Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756  
BILLINGS MT 59103-1756

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	3/26/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
<b>4784</b>			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/21/2005	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, MLLD Line Tightness Testing	
8,000					
2	30	3/26/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
<b>4785</b>			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Ggalvanic
Gasoline		7/21/2005	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, MLLD Line Tightness Testing	
8,000					
4	24	9/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
<b>4786</b>			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/21/2005	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, MLLD Line Tightness Testing	
4,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** JERRYS HIWAY SERVICE  
1901 N LAST CHANCE GULCH  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-05099

**Last Inspected On:** 9/12/2013

**Operating Permit Renewal Date:**

**Contact:** Jerry Fetters, (406) 207-3729

**Owners/Operators:** Jerold Fetters, Owner

(406)-442-5087

1901 N LAST CHANCE GULCH  
HELENA MT 59601-0742

Sharon Fetters, UST Class A Operator

Sharon Fetters, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	43	11/22/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1053</b>			Lined Interior/Impressed Current	Double-Walled	Yes
Temporarily Out of Use		6/1/2008	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Gasoline		11/3/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000					
2	43	11/22/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>4419</b>			Lined Interior/Impressed Current	Double-Walled	Yes
Temporarily Out of Use		6/1/2008	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		11/3/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					
3	43	11/22/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1055</b>			Lined Interior/Impressed Current	Double-Walled	Yes
Temporarily Out of Use		6/1/2008	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Gasoline		11/3/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** GREEN MEADOW MARKET  
3300 GREEN MEADOW DR  
HELENA, MT 59602 LEWIS AND CLARK

**Contact:** John J Rule, (406) 442-7095

**Sys Fac ID:** 25-05688  
**Last Inspected On:** 7/26/2013  
**Operating Permit Renewal Date:** 8/13/2016

**Owners/Operators:** JTA Inc, Owner (406)-442-7095 3300 GREEN MEADOW DR  
HELENA MT 59602-7707

Todd Adams, UST Class A Operator  
John Rule, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	36	10/1/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3243</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/9/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		11/20/2012	TLS-300 , Veeder Root		
2	36	10/1/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3244</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/9/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/20/2012	TLS-300 , Veeder Root		
3	08	8/8/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>5135</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		8/9/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
8,000		11/20/2012	TLS-300 , Veeder Root		
4	08	8/8/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>5136</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		8/9/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,000		11/20/2012	TLS-300 , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** ZIP TRIP 43  
1318 EUCLID AVE  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-05774

**Last Inspected On:** 10/7/2014

**Operating Permit Renewal Date:** 3/13/2018

**Contact:** Monte Means, (406) 442-9402

**Owners/Operators:** CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE  
SPOKANE VALLEY WA 99216  
Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE  
SPOKANE VALLEY WA 99216  
Tom Savas, UST Class A Operator  
Luci Tuttle, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	31	4/26/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>4518</b>			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	32	4/26/1983	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>4519</b>			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		
4	18	4/23/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>4520</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** GATES OF THE MOUNTAINS INC  
PO BOX 4478  
HELENA, MT 59604 LEWIS AND CLARK  
**Contact:** Tim Crawford, (406) 458-5241

**Sys Fac ID:** 25-06619  
**Last Inspected On:** 3/25/2013  
**Operating Permit Renewal Date:** 4/30/2016

**Owners/Operators:** Gates of The Mountains Inc, Owner (406)-458-5241 PO BOX 4478  
HELENA MT 59604-4478  
Timothy Crawford, UST Class A Operator  
Timothy Crawford, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	29	4/29/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
<b>1202</b>			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		3/25/2013	Manual Interstitial Monitor	MLLD Line Tightness Testing	
5,000		3/25/2013			
4	29	4/29/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
<b>1203</b>			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		3/25/2013	Manual Interstitial Monitor	MLLD Line Tightness Testing	
1,000		3/25/2013			

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** MDOT HELENA HEADQUARTERS  
2701 PROSPECT AVE  
HELENA, MT 59601 LEWIS AND CLARK

**Contact:** Joe Radonich, (406) 444-9204

**Sys Fac ID:** 25-06849  
**Last Inspected On:** 6/11/2014  
**Operating Permit Renewal Date:** 11/19/2017

**Owners/Operators:** MDOT Helena, Owner (406)-444-6200 KIM JANZEN  
PO BOX 201001  
HELENA MT 59620-1001

Joseph J Radonich, Operator (406)-444-9204 MDT  
DEADHEAD  
HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator  
Walt Kerttula, UST Class A Operator  
Mike Murolo, UST Class A Operator  
Joe Radonich, UST Class A Operator  
Tim Clark, UST Class B Operator  
Walter Jester, UST Class B Operator  
Bob Maphies, UST Class B Operator  
Jim Adolph, UST Class B Global Operator  
Bradley Becker, UST Class B Global Operator  
Dennis Grimm, UST Class B Global Operator  
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	19	3/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2911</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1	
12,000		6/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	19	3/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2912</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1	
12,000		6/10/2014	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** SOUTHS COUNTRY STORE  
3105 YORK RD  
HELENA, MT 59602 LEWIS AND CLARK

**Sys Fac ID:** 25-07353  
**Last Inspected On:** 8/24/2013  
**Operating Permit Renewal Date:** 9/23/2016

**Contact:** Lonnie Bennett, (406) 227-5757

**Owners/Operators:** L&B LLP, Owner (406)-227-5757 3487 BIRKLAND DR  
HELENA MT 59602-9196  
Lonnie Bennett, UST Class A Operator  
Lonnie Bennett, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	22	5/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3562</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/8/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		2/3/2015			
4	22	5/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3563</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/8/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		2/3/2015			

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** BOBS VALLEY SERVICE INC UST  
7507 N MONTANA AVE  
HELENA, MT 59602 LEWIS AND CLARK

**Sys Fac ID:** 25-07404

**Last Inspected On:** 12/9/2014

**Operating Permit Renewal Date:** 3/26/2018

**Contact:** Steve Bartmess, (406) 458-5140

**Owners/Operators:** Bobs Valley Service Inc, Owner (406)-458-5140 7507 N MONTANA AVE  
HELENA MT 59602-9389

Stephen Bartmess, UST Class A Operator  
Craig Sprankle, UST Class B Operator  
Stephen Bartmess, UST Class B Global Operator  
Steve Nummerdor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	27	3/27/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>474</b>			None	Double-Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	ELLD Line Tightness Testing, Not Listed	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
5	27	3/27/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>475</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/15/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
6	23	6/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>476</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/15/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes



## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** BOBS VALLEY SERVICE INC UST  
7507 N MONTANA AVE  
HELENA, MT 59602 LEWIS AND CLARK

**Sys Fac ID:** 25-07404  
**Last Inspected On:** 12/9/2014  
**Operating Permit Renewal Date:** 3/26/2018

**Contact:** Steve Bartmess, (406) 458-5140

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	17	11/15/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>477</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/15/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** Queen City Exxon LLC  
1721 CEDAR ST  
HELENA, MT 59601 LEWIS AND CLARK

**Contact:** Mike Bakker, (406) 442-0540

**Sys Fac ID:** 25-07848  
**Last Inspected On:** 3/16/2015  
**Operating Permit Renewal Date:** 8/27/2018

**Owners/Operators:** Queen City Exxon LLC, Owner (406)-439-4469 5755 OGLE VIEW RD  
HELENA MT 59601  
Timothy C Hornbacher, UST Class A Operator  
Mike Bakker, UST Class B Operator  
Timothy C Hornbacher, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
<b>1399</b>			None	None	Yes
Currently in Use		9/4/2006	Not Required	Gravity Feed	Galvanic
Waste Oil		3/16/2015	Automatic Tank Gauging 0.2	Deferred	
1,000		9/1/2004	Gilbarco EMC Basic , Gilbarco		
3	28	12/29/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
<b>1398</b>			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/1/2004	Gilbarco EMC Basic , Gilbarco		
4	28	12/29/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
<b>1396</b>			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/1/2004	Gilbarco EMC Basic , Gilbarco		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** Queen City Exxon LLC  
 1721 CEDAR ST  
 HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** Mike Bakker, (406) 442-0540

**Sys Fac ID:** 25-07848  
**Last Inspected On:** 3/16/2015  
**Operating Permit Renewal Date:** 8/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	28	12/29/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1397			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/1/2004	Gilbarco EMC Basic , Gilbarco		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** THRIFTWAY SUPER STOP 9  
1405 EUCLID AVE  
HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** (406) 449-0017

**Sys Fac ID:** 25-07931  
**Last Inspected On:** 6/5/2013  
**Operating Permit Renewal Date:** 6/12/2016

**Owners/Operators:** Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE  
BUTTE MT 59701-3553

Louie Sutey, UST Class A Operator  
Mike Uphus, UST Class A Operator  
Jeff Hoock, UST Class B Operator  
Peggy Johnson, UST Class B Operator  
Lisa Weist, UST Class B Operator  
Jack Hook, UST Class B Global Operator  
Louie Sutey, UST Class B Global Operator  
Lisa Weist, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	19	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2056</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000					
7	19	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2057</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000					
8	19	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, Not Applicable
<b>2058</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** HOLIDAY STATIONSTORE 270  
401 EUCLID AVE  
HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** (406) 443-0135

**Sys Fac ID:** 25-08067  
**Last Inspected On:** 6/10/2014  
**Operating Permit Renewal Date:** 9/9/2017

**Owners/Operators:** Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR  
PO BOX 1224  
MINNEAPOLIS MN 55437-1123

Jack Krueger Jr, UST Class A Operator  
Stephen Reckinger, UST Class A Operator  
Dave Samson, UST Class B Operator  
Jack Krueger Jr, UST Class B Global Operator  
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	28	5/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
<b>3017</b>			Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/11/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000		1/5/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	28	5/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
<b>3018</b>			Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/11/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		1/22/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	28	11/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
<b>3019</b>			Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/11/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000		11/28/2010	TLS-350/Gilbarco EMC , Veeder Root		
4	28	11/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
<b>3020</b>			Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/11/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000		11/4/2010	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** MONROE'S HIGH COUNTRY TRAVEL PLAZA  
3122 E US HIGHWAY 12  
HELENA, MT 59601 LEWIS AND CLARK

**Contact:** Jirsa Patricia, (406) 442-3259

**Sys Fac ID:** 25-08659  
**Last Inspected On:** 1/17/2014  
**Operating Permit Renewal Date:** 3/15/2017

**Owners/Operators:** Monroes High Country Travel Plaza LLC, Owner (406)-459-6633 3122 E US HIGHWAY 12  
HELENA MT 59601-9701  
Marvin Monroe, Operator (406)-459-6633 5400 SILVER CREEK RD  
HELENA MT 59602  
DEBRA MONROE, UST Class A Operator  
Marvin Monroe, UST Class A Operator  
DEBRA MONROE, UST Class B Operator  
Marvin Monroe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	6/19/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>4526</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
2	25	6/19/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>4527</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
8	19	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4528</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
9	19	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4529</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** MONROE'S HIGH COUNTRY TRAVEL PLAZA  
3122 E US HIGHWAY 12  
HELENA, MT 59601 LEWIS AND CLARK

**Contact:** Jirsa Patricia, (406) 442-3259

**Sys Fac ID:** 25-08659  
**Last Inspected On:** 1/17/2014  
**Operating Permit Renewal Date:** 3/15/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	19	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4530</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
11	19	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4531</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA 1  
1240 PROSPECT AVE  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-08706

**Last Inspected On:** 3/25/2013

**Operating Permit Renewal Date:** 6/29/2016

**Contact:** Trent Biggers, (406) 497-6700

**Owners/Operators:** Town Pump of Helena Inc, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	32	4/15/1983	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>2506</b>			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/14/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					
2	32	4/15/1983	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>2507</b>			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/14/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					
3	32	4/15/1983	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>2508</b>			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/14/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					
7	17	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2509</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/12/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000					



## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA 1  
1240 PROSPECT AVE  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-08706  
**Last Inspected On:** 3/25/2013  
**Operating Permit Renewal Date:** 6/29/2016

**Contact:** Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	17	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2510</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/12/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA 2  
1140 EUCLID AVE  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-08707

**Last Inspected On:** 3/25/2013

**Operating Permit Renewal Date:** 6/29/2016

**Contact:** Trent Biggers, (406) 497-6700

**Owners/Operators:** Town Pump of Helena Inc, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	31	4/14/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4832</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		4/25/2013	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000					
4	24	7/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4833</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2005	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
5	24	7/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4834</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2005	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
6	24	7/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4835</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** EXXON MARKETING HELENA TERMINAL  
3120 E US HIGHWAY 12  
HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** J R West, (406) 442-4190

**Sys Fac ID:** 25-08728  
**Last Inspected On:** 1/8/2013  
**Operating Permit Renewal Date:** 5/25/2016

**Owners/Operators:** Exxon Company USA Helena, Owner (406)-442-4190 PO BOX 4849  
HELENA MT 59604-4849  
James Vokral Sup, UST Class A Operator  
Christopher Scott Martin, UST Class B Operator  
Jim Gullon, UST Class B Global Operator  
Marc Larson, UST Class B Global Operator  
James Vokral Sup, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
<b>2774</b>	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		9/23/2011	Deferred	MLLD Line Tightness Testing	
638,000		12/20/2012			
12	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
<b>2772</b>	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		9/23/2011	Deferred	MLLD Line Tightness Testing	
1,200,000		12/20/2012			
14	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
<b>2770</b>	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		9/23/2011	Deferred	MLLD Line Tightness Testing	
604,000		12/20/2012			
16	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
<b>2768</b>	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		9/23/2011	Deferred	MLLD Line Tightness Testing	
603,330		12/20/2012			

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** EXXON MARKETING HELENA TERMINAL  
3120 E US HIGHWAY 12  
HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** J R West, (406) 442-4190

**Sys Fac ID:** 25-08728  
**Last Inspected On:** 1/8/2013  
**Operating Permit Renewal Date:** 5/25/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
26	29	1/1/1987	Bare Steel	Flexible Plastic	
<b>2786</b>	Yes		Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		9/23/2011	Deferred	MLLD Line Tightness Testing	
1,000		12/20/2012			
28	29	1/1/1987	Bare Steel	Flexible Plastic	
<b>2783</b>	Yes		Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		9/23/2011	Deferred	MLLD Line Tightness Testing	
3,000		12/20/2012			
30	29	1/1/1987	Bare Steel	Flexible Plastic	
<b>2780</b>	Yes		Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		9/23/2011	Deferred	MLLD Line Tightness Testing	
10,000		12/20/2012			
32	29	1/1/1987	Cathodically Protected Steel	Steel	High Level Alarm
<b>2767</b>			Double-Walled	none	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Mixture		9/23/2011	Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,000		12/12/2012			
35	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
<b>2778</b>	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		9/23/2012	Deferred	MLLD Line Tightness Testing	
633,000		12/20/2012			

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** HELENA MAIN CENTRAL OFFICE  
 441 N PARK AVE  
 HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** kevin robison, (801) 237-5334

**Sys Fac ID:** 25-08775  
**Last Inspected On:** 6/10/2014  
**Operating Permit Renewal Date:** 10/18/2017

**Owners/Operators:** Qwest Corporation, Owner (801)-237-3006 250 E 200 S #1601  
 SALT LAKE CITY UT 84111  
 Qwest Corporation, Operator (801)-237-3006 250 E 200 S #1601  
 SALT LAKE CITY UT 84111  
 Kevin Robison, UST Class A Operator  
 Kevin Robison, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	1/1/1992	Fiberglass Reinforced Plastic	Steel	High Level Alarm
1728			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
2,500		11/12/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** FEDERAL RESERVE BANK HELENA  
100 NEILL AVE  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-11291  
**Last Inspected On:** 7/21/2014  
**Operating Permit Renewal Date:** 1/9/2018

**Contact:** Ron Hicks, (406) 447-3946

**Owners/Operators:** Federal Reserve Bank, Owner (406)-447-3940 100 NEILL AVE  
HELENA MT 59601-3329  
Ron Hicks Jr, UST Class A Operator  
Ron Hicks Jr, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	26	10/1/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2322			None	Double-Walled	Yes
Currently in Use			Not Required	Pressurized	Galvanic
Heating Oil		7/21/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000		11/27/2012	TLS-300 , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** ZIP TRIP 42  
3100 N MONTANA AVE  
HELENA, MT 59602 LEWIS AND CLARK  
**Contact:** (406) 449-8766

**Sys Fac ID:** 25-12353  
**Last Inspected On:** 10/7/2014  
**Operating Permit Renewal Date:** 3/2/2018

**Owners/Operators:** CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE  
SPOKANE VALLEY WA 99216  
Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE  
SPOKANE VALLEY WA 99216  
Tom Savas, UST Class A Operator  
Luci Tuttle, UST Class B Operator  
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	6/7/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>561</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/17/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	24	6/7/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>559</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/17/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	24	6/7/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>560</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/17/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** LAST CHANCE RENTAL & LEASING LLP  
3122 AIRPORT ROAD  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-12834

**Last Inspected On:** 7/10/2014

**Operating Permit Renewal Date:** 8/19/2017

**Contact:** John Maxness, (406) 442-2190

**Owners/Operators:** Last Chance Rental & Leasing LLP, Owner (406)-442-2190 2430 AIRPORT ROAD  
HELENA MT 59601  
John Maxness, Operator (406)-422-2190 2430 AIRPORT RD  
HELENA MT 59601  
John Maxness, UST Class A Operator  
John Maxness, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	9/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4444			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		7/1/2014	TS-1000 , Incon	Continuous Interstitial Monitor	



## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** WATKINS & SHEPARD TRUCKING HELENA  
1500 BLAINE ST  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-12917

**Last Inspected On:** 7/2/2014

**Operating Permit Renewal Date:** 7/18/2017

**Contact:** Farren Flynn, (406) 442-9536

**Owners/Operators:** Watkins & Shepard Trucking, Owner

(406)-728-6121

PO BOX 5328

MISSOULA MT 59806-5328

Brandon Dulaney, UST Class A Operator

Brandon Dulaney, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	2/3/1993	Cathodically Protected Steel	Steel	
<b>4458</b>		7/2/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		6/11/2014	Manual Interstitial Monitor	Continuous Interstitial Monitor	
2,000			TLS-300 , Veeder Root		
2	23	2/3/1993	Cathodically Protected Steel	Steel	
<b>4459</b>		7/2/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		6/11/2014	Manual Interstitial Monitor	Continuous Interstitial Monitor	
500			TLS-300 , Veeder Root		
3	20	11/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>4460</b>		7/2/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		6/11/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-300 , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** LAKESIDE GENERAL STORE  
5330 YORK RD  
HELENA, MT 59602 LEWIS AND CLARK  
**Contact:** Thomas Morrison, (406) 443-1040

**Sys Fac ID:** 25-13657  
**Last Inspected On:** 2/2/2015  
**Operating Permit Renewal Date:** 3/30/2018

**Owners/Operators:** Juniper Hill Farm LLC, Owner (406)-443-1040 111 N LAST CHANCE GULCH STE 3B  
HELENA MT 59601-4144  
Lakeside General Store LLC, Operator (406)-443-1040 111 N LAST CHANCE GULCH, 3B  
HELENA MT 59601  
Penny Hunsaker, UST Class A Operator  
JoAnn Priebe, UST Class A Operator  
Kathleen Schendel, UST Class A Operator  
Penny Hunsaker, UST Class B Operator  
Kathleen Schendel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	7/24/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4552</b>			None	None	Yes
Currently in Use		7/24/2005	Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		2/3/2015	TLS-300 , Veeder Root		
2	20	7/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4553</b>			None	None	Yes
Currently in Use		7/1/2005	Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		2/3/2015	TLS-300 , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** HELENA AUTO CENTER LLC  
3401 HIGHWAY 12 E  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-13687

**Last Inspected On:** 8/21/2014

**Operating Permit Renewal Date:** 8/28/2017

**Contact:** Ken Beckler, (406) 442-5810

**Owners/Operators:** Helena Auto Center LLC, Owner/Operator

(406)-442-5810

PO BOX 6549

HELENA MT 59604

Deann Horning, UST Class A Operator

Howard Reed, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	3/15/1996	Cathodically Protected Steel	Steel	
1244			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Waste Oil		3/25/2014	Manual Interstitial Monitor	Deferred	
8,000		8/22/2014			

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** SLEEPING GIANT CONVENIENCE STORE  
3425 E US HIGHWAY 12  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-13763

**Last Inspected On:** 8/1/2013

**Operating Permit Renewal Date:** 8/13/2016

**Contact:** Chad Bachmeier, (406) 202-2090

**Owners/Operators:** Sleeping Giant Holding LLC, Owner (406)-443-5050 PO BOX 5807  
HELENA MT 59604  
Sleeping Giant Convenience Store LLC, Operator (406)-443-5050 3423 E US HIGHWAY 12  
HELENA MT 59604  
Todd Bachmeier, UST Class A Operator  
Mike Clasby, UST Class A Operator  
Mike Clasby, UST Class B Operator  
Todd Bachmeier, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>365</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
8,000		8/1/2013			
2	19	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>366</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
5,000		8/1/2013			
3	19	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4333</b>			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
8,000		8/1/2013			

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** SLEEPING GIANT CONVENIENCE STORE  
 3425 E US HIGHWAY 12  
 HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 25-13763  
**Last Inspected On:** 8/1/2013  
**Operating Permit Renewal Date:** 8/13/2016

**Contact:** Chad Bachmeier, (406) 202-2090

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	19	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
368			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line	
				Tightness Testing	
5,000		8/1/2013			

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA 6  
2401 N MONTANA AVE  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 56-13818

**Last Inspected On:** 3/25/2013

**Operating Permit Renewal Date:** 6/29/2016

**Contact:** Todd Fickler, (406) 443-5068

**Owners/Operators:** Park Street Holdings LLC, Owner (406)-467-6700 PO BOX 6000  
BUTTE MT 59702-6000  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	9/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>4610</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					
2	18	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>3443</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** ARMY AVIATION SUPPORT FACILITY  
3333 SKYWAY DR  
HELENA, MT 59602 LEWIS AND CLARK  
**Contact:** Adel Johnson, (406) 324-3089

**Sys Fac ID:** 56-13821  
**Last Inspected On:** 9/29/2015  
**Operating Permit Renewal Date:** 2/9/2019

**Owners/Operators:** US Dept of Military Affairs Helena, Owner/Operator (406)-324-3000 PO BOX 4789  
FORT HARRISON MT 59636-4789

Howard Eich, UST Class A Operator  
Adel Johnson, UST Class A Operator  
Thad Waples, UST Class A Operator  
Kenneth Brug, UST Class B Operator  
Michonne Cronquist, UST Class B Operator  
Dave Goroski, UST Class B Operator  
James Grigsby, UST Class B Operator  
Mark Hall, UST Class B Operator  
Adel Johnson, UST Class B Operator  
David Johnson, UST Class B Operator  
Adam Mckinlay, UST Class B Operator  
James Scott, UST Class B Operator  
Michael Steinberg, UST Class B Operator  
Michael Young, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	3/1/1997	Fiberglass Reinforced Plastic	No Piping	Positive Shutoff, High Level Alarm
<b>827</b>			Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor		
25,000			Gilbarco EMC Basic , Gilbarco		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** ARMY AVIATION SUPPORT FACILITY  
3333 SKYWAY DR  
HELENA, MT 59602 LEWIS AND CLARK

**Sys Fac ID:** 56-13821  
**Last Inspected On:** 9/29/2015  
**Operating Permit Renewal Date:** 2/9/2019

**Contact:** Adel Johnson, (406) 324-3089

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	18	3/1/1997	Fiberglass Reinforced Plastic	No Piping	Positive Shutoff, High Level Alarm
<b>828</b>			Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor		
25,000			Gilbarco EMC Basic , Gilbarco		



## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** DAVES EXPRESS LUBE  
4990 N MONTANA AVE  
HELENA, MT 59602 LEWIS AND CLARK

**Sys Fac ID:** 56-13828

**Last Inspected On:** 2/28/2013

**Operating Permit Renewal Date:** 7/27/2016

**Contact:** David Clemens, (406) 449-9667

**Owners/Operators:** Dave's Express Lube Inc, Owner (406)-449-9667 4990 N MONTANA AVE  
HELENA MT 59602-7268  
Dave Clemens, UST Class A Operator  
Dave Clemens, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	1/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>372</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
2	18	1/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>373</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000					
3	18	1/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>374</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
4	18	1/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>375</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** MERGENTHALER TRANSFER & STORAGE CARTER DR  
1430 CARTER DR  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 56-13831

**Last Inspected On:** 12/10/2014

**Operating Permit Renewal Date:** 3/19/2018

**Contact:** Travis Sandau, (406) 443-7964

**Owners/Operators:** Mergenthaler Transfer & Storage, Owner (406)-443-7964 1430 CARTER DR  
HELENA MT 59601-6429  
Dave Gardner, UST Class A Operator  
Dave Gardner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	11/1/1997	Cathodically Protected Steel	Flexible Plastic	
1609			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		12/10/2014	Manual Interstitial Monitor	Manual Interstitial Monitor	
3,000		12/10/2014		MLLD Line Tightness Testing	

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA 4  
2900 N MONTANA AVE  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 56-13846

**Last Inspected On:** 3/25/2013

**Operating Permit Renewal Date:** 6/29/2016

**Contact:** Trent Biggers, (406) 497-6700

**Owners/Operators:** Capitol Town Pump Inc, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000  
Trent Biggers, UST Class A Operator  
Megan Gretch, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	17	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2680</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	17	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2681</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
3	17	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2682</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA 4  
2900 N MONTANA AVE  
HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 56-13846  
**Last Inspected On:** 3/25/2013  
**Operating Permit Renewal Date:** 6/29/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	17	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2683</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	17	7/24/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2684</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
6	14	9/7/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4671</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** HOLIDAY #723  
600 N FEE ST  
HELENA, MT 59601 LEWIS AND CLARK

**Contact:** (952) 830-8899

**Sys Fac ID:** 56-13956  
**Last Inspected On:** 11/2/2015  
**Operating Permit Renewal Date:** 3/30/2019

**Owners/Operators:** Rocky Mountain Oil Inc, Owner (952)-830-8700 ATTN: ENVIRONMENTAL DIRECTOR  
4567 AMERICAN BLVD W  
BLOOMINGTON MN 55437

Holiday #723, Operator (952)-830-8747 606 N FEE ST  
HELENA MT 59601

Robert Deninno, UST Class A Operator  
Kegan Krueger, UST Class A Operator  
Stephen Reckinger, UST Class A Operator  
Ryan Coey, UST Class B Operator  
Craig Hagmeier, UST Class B Operator  
Cynthia Hellwitz, UST Class B Operator  
Stephen Reckinger, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	16	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
<b>4128</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000		8/2/2015	TLS-450 , Veeder Root		
2	16	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
<b>4129</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
10,000		12/22/2015	TLS-450 , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** SAFEWAY GASOLINE HELENA  
611 N MONTANA AVE  
HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** (406) 442-6631

**Sys Fac ID:** 56-14000  
**Last Inspected On:** 8/26/2013  
**Operating Permit Renewal Date:** 1/29/2017

**Owners/Operators:** Safeway Stores Inc, Owner (425)-455-6545 1121 124TH AVE NE  
BELLEVUE WA 98005-2101

Heath Brown, UST Class A Operator  
Aaron Nelson, UST Class A Operator  
Lynn Pehrson, UST Class A Operator  
Heath Brown, UST Class B Operator  
ANITA L JOHNSON, UST Class B Operator  
Justin W Smith, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	14	6/1/2001	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
<b>4330</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000					
2	14	6/1/2001	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
<b>4331</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** SAFEWAY GASOLINE HELENA  
 611 N MONTANA AVE  
 HELENA, MT 59601 LEWIS AND CLARK  
**Contact:** (406) 442-6631

**Sys Fac ID:** 56-14000  
**Last Inspected On:** 8/26/2013  
**Operating Permit Renewal Date:** 1/29/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	14	6/1/2001	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4332			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** SPRINT HELENA POP  
1100 PHOENIX AVE  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 56-14011

**Last Inspected On:** 3/17/2014

**Operating Permit Renewal Date:** 8/8/2017

**Contact:** Sara Cullen-Crafton, (913) 315-8624

**Owners/Operators:** Sprint Communications Co LLP, Owner (913)-762-5957 PO BOX 7994  
SHAWNEE MISSION KS 66251-6106

Brian Wiedower, UST Class A Operator  
Doug Dickinson, UST Class B Operator  
Scott Hallesy, UST Class B Operator  
Brandon Hyde, UST Class B Operator  
Nikki Lattin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
<b>4322</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,500		2/17/2014			



## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA 5  
1822 E CUSTER AVE  
HELENA, MT 59602 LEWIS AND CLARK

**Sys Fac ID:** 60-15029

**Last Inspected On:** 3/25/2013

**Operating Permit Renewal Date:** 6/19/2016

**Contact:** Trent Biggers, (406) 497-6700

**Owners/Operators:** Main Street Holdings LLC, Owner (406)-497-6700 600 S MAIN ST  
BUTTE MT 59701-2534  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>5064</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
20,000		12/7/2006			
2	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>5065</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		12/7/2006			
3	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>5066</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000		12/11/2006			

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA 5  
1822 E CUSTER AVE  
HELENA, MT 59602 LEWIS AND CLARK  
**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 60-15029  
**Last Inspected On:** 3/25/2013  
**Operating Permit Renewal Date:** 6/19/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>5067</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		12/11/2006			
5	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>5068</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000		12/15/2006			
6	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>5074</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		12/15/2006			

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** Costco Gasoline 633  
CUSTER AVE & WASHINGTON ST  
HELENA, MT 59602 LEWIS AND CLARK

**Sys Fac ID:** 60-15051  
**Last Inspected On:** 7/10/2014  
**Operating Permit Renewal Date:** 11/13/2017

**Contact:** Dennis Bock, (425) 427-7653

**Owners/Operators:** Costco Wholesale, Owner (425)-313-8100 ATTN: LICENSING  
PO BOX 35005  
SEATTLE WA 98124-8990

Dennis Bock, UST Class A Operator  
Andrew Erdahl, UST Class A Operator  
Chris Hazelett, UST Class A Operator  
Jonathan Listar, UST Class A Operator  
Daniel Manibusan, UST Class A Operator  
Dan Martinez, UST Class A Operator  
Stan Murray, UST Class A Operator  
Dave Preston, UST Class A Operator  
Michael Schaeffer, UST Class A Operator  
Patrick Brand, UST Class B Operator  
Andrew Erdahl, UST Class B Operator  
Chris Hazelett, UST Class B Operator  
Daniel Manibusan, UST Class B Operator  
Steve Miller, UST Class B Operator  
Stan Murray, UST Class B Operator  
Dave Preston, UST Class B Operator  
Dennis Bock, UST Class B Global Operator  
Andrew Erdahl, UST Class B Global Operator  
Jonathan Listar, UST Class B Global Operator  
Michael Schaeffer, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	09	10/5/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5095			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
30,000		11/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** Costco Gasoline 633  
CUSTER AVE & WASHINGTON ST  
HELENA, MT 59602 LEWIS AND CLARK

**Contact:** Dennis Bock, (425) 427-7653

**Sys Fac ID:** 60-15051  
**Last Inspected On:** 7/10/2014  
**Operating Permit Renewal Date:** 11/13/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	09	10/5/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>5096</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
30,000		11/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	09	10/5/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>5097</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
30,000		11/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	04	4/12/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>5281</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Hazardous Substance			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,500		11/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** MDT EQUIPMENT DEVELOPMENT BUILDING  
490 18TH ST  
HELENA, MT 59601 LEWIS AND CLARK

**Sys Fac ID:** 60-15139

**Last Inspected On:** 4/7/2014

**Operating Permit Renewal Date:** 5/15/2017

**Contact:** Doug Olson, (406) 444-3060

**Owners/Operators:** Montana Dept of Administration, Owner (406)-444-3060 CAPITOL ANNEX GENERAL SERVICES DIVISION  
1310 E LOCKEY  
HELENA MT 59620

Tom Russ, UST Class A Operator  
Ed Sivils, UST Class A Operator  
Carl Edgar, UST Class B Operator  
Tom Mandeville, UST Class B Operator  
Daniel Messerli, UST Class B Operator  
Edward Naccarato, UST Class B Operator  
James Simmons, UST Class B Operator  
Ed Sivils, UST Class B Operator  
David Spradlin, UST Class B Operator  
Brian Taylor, UST Class B Operator  
Zane Rudolph, UST Class B Global Operator  
Tom Russ, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	06	10/1/2009	Aboveground Tank	Flexible Plastic	
<b>5214</b>	Yes	4/7/2014	None	Double-Walled	No
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
4,000					Yes
2	03	10/1/2012	Aboveground Tank	Flexible Plastic	
<b>5386</b>	Yes	10/31/2012	None	Double-Walled	No
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
4,000				Not Listed	Yes

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA #3  
3161 N SANDERS  
HELENA, MT 59602 LEWIS AND CLARK

**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 60-15210  
**Last Inspected On:** 12/2/2015  
**Operating Permit Renewal Date:** 3/18/2019

**Owners/Operators:** Capitol Town Pump Inc, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000

Trent Biggers, Operator (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator  
Trent Biggers, UST Class A Operator  
Charles A Armstrong, UST Class B Global Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	03	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
<b>5367</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
2	03	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>5369</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
3	03	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>5370</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

## Facility Summary in LEWIS AND CLARK County in the City of HELENA

**Location:** TOWN PUMP INC HELENA #3  
 3161 N SANDERS  
 HELENA, MT 59602 LEWIS AND CLARK  
**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 60-15210  
**Last Inspected On:** 12/2/2015  
**Operating Permit Renewal Date:** 3/18/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	03	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>5371</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
5	03	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>5372</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

## Facility Summary in LEWIS AND CLARK County in the City of LINCOLN

**Location:** MOUNTAIN VIEW COOP LINCOLN  
525 MAIN STREET  
LINCOLN, MT 59639 LEWIS AND CLARK  
**Contact:** Chester Kallem, (406) 453-2435

**Sys Fac ID:** 25-03995  
**Last Inspected On:** 8/19/2014  
**Operating Permit Renewal Date:** 10/16/2017

**Owners/Operators:** Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS  
2200 OLD HAVRE HWY  
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator  
Sharon Bell, UST Class B Operator  
Ranae Brown, UST Class B Operator  
David Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	7/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2255		7/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/14/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	19	7/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2252		7/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		8/14/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
6	19	7/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2253		7/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		8/14/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		



## Facility Summary in LEWIS AND CLARK County in the City of LINCOLN

**Location:** MOUNTAIN VIEW COOP LINCOLN  
525 MAIN STREET  
LINCOLN, MT 59639 LEWIS AND CLARK

**Sys Fac ID:** 25-03995  
**Last Inspected On:** 8/19/2014  
**Operating Permit Renewal Date:** 10/16/2017

**Contact:** Chester Kallem, (406) 453-2435

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	19	7/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>2254</b>		7/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/14/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in LEWIS AND CLARK County in the City of WOLF CREEK

**Location:** CANYON STORE EXXON  
175 RECREATION RD  
WOLF CREEK, MT 59648 LEWIS AND CLARK

**Contact:** Shawn Otheim, (775) 527-4507

**Sys Fac ID:** 25-04132  
**Last Inspected On:** 10/16/2014  
**Operating Permit Renewal Date:** 3/27/2018

**Owners/Operators:** Otheim Family LLC, Owner (406)-235-4111 175 RECREATION ROAD  
WOLF CREEK MT 59648

Shawn Otheim, Operator (406)-235-4111 175 RECREATION ROAD  
WOLF CREEK MT 59648

Shawn Otheim, UST Class A Operator  
Shawn Otheim, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	11/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>3483</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
3,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	17	11/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>3484</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	17	11/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>3946</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in LEWIS AND CLARK County in the City of WOLF CREEK

**Location:** BOAT LOFT  
1460 BEARTOOTH RD  
WOLF CREEK, MT 59648 LEWIS AND CLARK

**Sys Fac ID:** 25-05921

**Last Inspected On:** 11/4/2014

**Operating Permit Renewal Date:** 1/8/2018

**Contact:** Marshall Trainor, (406) 452-3622

**Owners/Operators:** Driftwood Enterprises LLC, Owner (406)-235-4435 PO BOX 3386  
GREAT FALLS MT 59403-3386

Marshall J Trainor, UST Class A Operator

Mike Liggett, UST Class B Operator

Chris Ryan, UST Class B Operator

Marshall J Trainor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	4/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
473			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
4,000				Continuous Interstitial Monitor	